

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 10 / 9.01.2023

Dated: 9/01/2023

It is certified that an inspection team headed by R.K. Sinda, Chemist / R.M  
 (Name of Officers with designation) from Laboratory Chemist Team,  
 (Name of Department/ Office) inspected the Public Health Engineering Deptt. Ajpur  
 (Name & Address of the school) on Adani Vidya Mandir Seelhi,  
Post - Surguja (C.G.) ( Name of school) and found that the  
 facilities for the students and members of staff of the institution and is maintaining the hygienic  
 sanitation condition in the school building & the campus as per norms prescribed by the Central/  
 State/ U.T. Govt.

The above is valid for a period of 1 year

Signature with Seal: R.K. Sinda  
 Name Kaishag Quality Manager  
 Designation District Water Testing Laboratory  
PHED, Ambikapur, Surguja (C.G.)

Name & Address of the Office / Department : PHED Ajpur

To  
Adani Vidya Mandir  
Seelhi  
Post - Surguja (C.G.)  
 (Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



**DISTRICT WATER TESTING LABORATORY**  
( National Drinking Water mission)

District- Surguja

**Samples**

- (i) Date of Collection- 05.01.2023
- (ii) Date of Received- 05.01.2023
- (iii) Date of Analysis - 05.01.2023

**Details of Source & Location**

✓ (i) Water sample :- Bore well

अदानी विद्या मंदिर

साल्ही, वि०ख०-उदयपुर,

जिला- सरगुजा(छ०ग०)

Note- water sample brought by self.

S No	Characteristics	Unit Table	Acceptable	Cause of rejection	Results						
					(i)	(ii)	(iii)	(iv)	(v)	(vi)	
<b>PHYSICAL</b>											
1	Temperature										
2	Turbidity	N.T.U	1.0	5.0	0.17						
3	Colour	Pt Cobalt Scale	5.0	25	5.00						
4	Taste&Odour	-	Unobjectionable	objectionable	Agr.						
<b>Chemical</b>											
5	pH	pH Scale	6.5 to 8.5	<6.5 or >9.2	7.02						
6	Conductivity	Micro mhos/cm									
7	Total Alkalinity	mg/l	200	600	31.00						
8	Chlorides	mg/l	200	1000	14.00						
9	Nitrates	mg/l	45	45	N.D.						
10	Total Hardness (as CaCO3)	mg/l	200	600	49.00						
11	Calcium (as ca)	mg/l	75	200	7.00						
12	Magnesium (as Mg)	mg/l	30	150	6.70						
13	Iron	mg/l	0.1	1.0	N.D.						
14	Fluorides	mg/l	1.0	1.5	0.16						
15	Sulphates (as SO4)	mg/l	200	400	7.00						
16	Total dissolved Solids	mg/l	500	2000	40.00						
17	Residual Chlorine	mg/l	0.2	1.0	N.D.						
18	Coagulant Dose(Jar tests)	mg/l	-	-	-						
19	Dissolve Oxygen	-	-	-	-						
20	B.O.D.	-	-	-	-						
21	C.O.D.	-	-	-	-						
<b>BACTERIOLOGICAL [H2S Vials Method]</b>											
22	Coli form organisms At 37° C	M.P.N/ 100ml	24 Hrs		Absent						
23	Faecal Coli form Special test-	Per 100 ml	48 Hrs		Absent						

REMARK - Get results are acceptable limit.

\* N.D.- Not Detected.

*K.K. Saha*  
Quality-Manager  
District Water Testing Laboratory  
PHED, Sambalpur, Surguja (O.G.)

